

# DISTRICT COUNCIL OF LOWER EYRE PENINSULA

## Electricity mains under road reserves

---



“Working with our Rural & Coastal Communities”

	<b>INF-POL-01 – ELECTRICITY MAINS UNDER ROAD RESERVE</b>	<b>Version No:</b>	2.1
		<b>Issued:</b>	May 2019
		<b>Next Review:</b>	May 2022

Responsibility:	Infrastructure
Minutes reference:	C144 (2)
Applicable Legislation:	Local Government Act 1999, S222
Related Policies/Procedures/Codes:	<a href="#">Application – Alteration of Road</a>
Review Frequency:	Following Council Elections

## 1. POLICY

All installations of electricity across or through road reserves must be undertaken by a qualified and currently licensed electrician in accordance with any relevant legislation and standards.

Any request for an installation greater than five (5) metres, must be an extension to the SA Power Networks infrastructure to ensure it is maintained and is shown on Dial Before You Dig plans.

Any request for installation less than 5 metres in length must first be approved by the Works Manager.

## 2. AVAILABILITY

Copies of this policy may be purchased for the fees outlined within Council's current Schedule of Fees & Charges. This policy is available for inspection at the Council offices during ordinary business hours or on Council's website ([www.lowereyrepeninsula.sa.gov.au](http://www.lowereyrepeninsula.sa.gov.au)) at no cost.

SIGNED:

.....  
CEO

Date: 17 / 05 / 2019

.....  
Mayor, DCLEP

Date: 17 / 05 / 2019

### DOCUMENT HISTORY

Version:	Issue Date:	Description of Change:
2.0	17/7/15	Adopted
2.1	17/5/19	Adopted