



District Council of Lower Eyre Peninsula

Working with our Rural and Coastal Communities

ADDENDUM – 21 JUNE 2019 DEVELOPMENT & ENVIRONMENTAL SERVICES

D50 DEVELOPMENT AND ENVIRONMENTAL SERVICES REPORT

DES/10/19 FARM BEACH CAMPGROUND WASTEWATER SYSTEM UPGRADE

A recent servicing of the aerobic wastewater treatment system at the Farm Beach Campground has revealed its deteriorating internal condition. Whilst the tank hasn't failed, it is heavily corroded on the inside and if left as it is would ultimately fail. As such it is recommended that the system be replaced as soon as possible. The estimated cost to remove the existing concrete system and replace with a new system of fibreglass construction is \$15,000 (ex GST).

The replacement of the tank can be considered as an asset renewal and therefore the funds would be sought from Council's Asset Sustainability allocation in the 2019/20 financial year.

RECOMMENDATION MDES

"That the replacement of the Farm Beach campground wastewater treatment system be included in the 2019/20 budget at an estimated cost of \$15,000; and

That the project be funded from Council's Asset Sustainability Allocation for the 2019/20 financial year."